



## County of Fairfax, Virginia

To protect and enrich the quality of life for the people, neighborhoods, and diverse communities of Fairfax County

February 13, 2008

Ron MacDonald, President  
See Water Inc.  
P.O. Box 1269  
San Jacinto, CA 92581

Subject: SEewater "Oil Smart" Pump Controller and Alarm System

Dear Mr. MacDonald:

We have reviewed the documentation you provided in regard to the subject equipment, and based on this information, we have determined that this equipment is code compliant for controlling the operation of "listed and labeled" automatic sump pumps used to provide drainage of elevator pits. Where installed in strict compliance with the manufacturer's installation instructions, and when used in conjunction with other "listed and labeled" components (e.g., sump pumps), the subsequent pump discharge may be directed to a storm water drain without the need for an intervening oil-water separator. Verification of proper equipment installation is subject to the "material" installation and "third party" requirements prescribed in the International Plumbing Code.

You may use this product approval letter for marketing purposes.

Sincerely,

Ray Pylant  
Building Official

LRP/gt

cc: Ray Pylant, Director, Commercial Inspections Division  
Audrey C. Clark, Director, Building Plan Review Division  
Patrick Nnaji, Chief Mechanical Inspector  
Guy Tomberlin, Chief Plumbing Inspector  
Jonathan Nixon, National Elevator Inspection Service

---

Department of Public Works and Environmental Services

Land Development Services

12055 Government Center Parkway, Suite 444

Fairfax, VA 22035-5504

Phone: 703-324-1780, 703-324-1980 TTY: 711, Fax: 703-324-1847

[www.fairfaxcounty.gov/dpwes/lds](http://www.fairfaxcounty.gov/dpwes/lds)

