



----- DASHED LINE INDICATES FIELD WIRING.

USE COPPER CONDUCTORS ONLY.
TEMPERATURE RATING OF CONDUCTORS IS TO BE 60°C (147°F).
BRANCH CIRCUIT PROTECTION SHALL BE PROVIDED BY THE INSTALLER. MUST BE SIZED ACCORDING TO PUMP/MOTOR MANUFACTURING SPECIFICATIONS.
VERIFY CORRECT OPERATION OF CONTROL PANEL AFTER INSTALLATION IS COMPLETE.

DATE BY	DATE	REV	DATE
DESIGNED BY	11/18/14	1	
SEE POWER			
THIS DRAWING CONFORMS TO THE NATIONAL ELECTRICAL CODE (NEC) AND ALL APPLICABLE REGULATIONS AND SHALL BE USED IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE (NEC) AND ALL APPLICABLE REGULATIONS.		DATE: 11/18/14	
DRAWN BY: 1805		PROJECT NO.: HTS-1X	
CHECKED BY: NONE		DATE: 11/18/14	
HTS-1X CONTROL SCHEMATIC			
HTS-1X 1 OF 1			